

SKYLINER FABRICS INC.

TEST REPORT

SCOPE OF WORKS

Client Specified Testing: Evaluate the strength of Insulation Facing system from Skyliner Fabrics Inc.

REPORT NUMBER

106099435CRT-001

ISSUE DATE

March 31, 2025

PAGES

5

DOCUMENT CONTROL NUMBER

GFT-OP-10a (6-March-2017)

© 2017 INTERTEK





Total Quality. Assured.

TEST REPORT FOR SKYLINER FABIRCS INC.

Report No.: 106099435CRT-001

Date: March 31, 2025

3933 US Route 11
Cortland, New York ,USA
13045

Telephone: 607-758-6246
Facsimile: None
www.intertek.com

David Tomchak
Director of Marketing
Skyliner Fabrics Inc.
P.O. Box 9229
Green Bay, WI 54308
USA
dtomchak@bayinsulation.com

Phone: +1 (920)-406-4000

Report Number..... : 106099435CRT-001

Signed Quote Number..... : Qu-01508767

PO Number.....: N/A

Name of Testing Laboratory

Preparing the Report: Intertek Testing Services NA Inc.

Test Specification:

Standard.....: Client Specified Testing: Evaluate the strength of
Insulation Facing system from Skyliner Fabrics Inc. (Ref
to OSHA 1926.502(c))

Date(s) of Testing.....: 03/25/2025

Product Description:

Product Type:: Insulation Facing system

Brand Name:: Skyliner Fabrics

Model Number(s):: Skyliner Fabrics Insulating Facing System

Date(s) Samples Received: N/A – Intertek Witness

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

TEST REPORT SKYLINER FABRICS INC.

Report No.: 106099435CRT-001

Date: March 31, 2025

SECTION 1

SUMMARY OF TESTING

TESTS COMPLETED	Client Specified Testing	STATUS
Safety Nets (Drop Test)	Ref OSHA 1926.502(c)	SEE RESULTS

SECTION 2

This test report concludes the work anticipated in the testing phase of your project. If there are any questions regarding this report please contact the undersigned at 607-753-6711.

COMPLETED BY:	Alex Smith	REVIEWED BY:	Matthew Stevens
TITLE:	Technician	TITLE:	Team Leader
SIGNATURE:		SIGNATURE:	
DATE	03/31/2025	DATE:	03/31/2025

Please see attached test data for details.

SECTION 3

TESTING EQUIPMENT CALIBRATION INFORMATION

Used for Test	Description	Manufacturer	Control No.	Model No.	Serial No.	Cal. Date	Cal. Due
X	Stop Watch	Fischer Scientific	N1179	NA	-	08/08/24	08/08/25
X	Tape Measure	Kobalt	H323	-	-	10/10/24	10/10/25

TEST REPORT SKYLINER FABRICS INC.

Report No.: 106099435CRT-001

Date: March 31, 2025

SECTION 4

SUPPLEMENTAL TEST DATA

SECTION (TEST)	REQUIREMENT	RESULTS		COMPLIANCE										
OSHA 1926.502(c)	Safety nets and safety net installations shall be drop-tested at the jobsite after initial installation and before being used as a fall protection system, whenever relocated, after major repair, and at 6-month intervals if left in one place. The drop-test shall consist of a 400-pound (180 kg) bag of sand 30 + or - 2 inches (76 + or - 5 cm) in diameter dropped into the net from the highest walking/working surface at which employees are exposed to fall hazards, but not from less than 42 inches (1.1 m) above that level.			SEE RESULTS										
		<table><tr><th>Test</th><th>Results</th></tr><tr><td>Weight of sand bag (lbs)</td><td>400 lbs.</td></tr><tr><td>Drop Height (minimum of 42")</td><td>42"</td></tr><tr><td>Sand bag contact surface under net during drop?</td><td>No</td></tr><tr><td>Did netting hold and retain load?</td><td>Yes</td></tr></table>		Test	Results	Weight of sand bag (lbs)	400 lbs.	Drop Height (minimum of 42")	42"	Sand bag contact surface under net during drop?	No	Did netting hold and retain load?	Yes	
Test	Results													
Weight of sand bag (lbs)	400 lbs.													
Drop Height (minimum of 42")	42"													
Sand bag contact surface under net during drop?	No													
Did netting hold and retain load?	Yes													
		The results apply only to the samples tested and are not intended as a certification.												

SECTION 5

REVISION HISTORY

REPORT NUMBER	DATE OF REVISION	DESCRIPTION OF CHANGE:	PROJECT OWNER	REVIEWED BY
106099435CRT-001	03/31/2025	Original Report	Alex Smith	Matthew Stevens

TEST REPORT SKYLINER FABRICS INC.

Report No.: 106099435CRT-001

Date: March 31, 2025

Section 6

PHOTOGRAPHS

Pre-Drop



Post Drop

